



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous & NAAC Accredited Institute Affiliated to RGPV, Bhopal, M.P.)

Gola ka Mandir, Gwalior (M.P.)- 474 005, INDIA

Ph.: +91-751-2409300, e-mail: director@mitsgwalior.in, website: www.mitsgwalior.in

TESTING / CONSULTANCY REPORT

Rev. 131

Civil/MKT/AKA/Env.Engg.Lab./ TR No. 303/No T06240/1689

Date: 20/9/22

To,
The Principal,
ITM Global School,
AH-43, Bypass Turari, Jhansi Road,
Gwalior (MP) - 474001



MITS Dispatch

Ref: Your letter No ITMGS/2022-23/399 dt. 26-08-2022.
Sub: Testing of Water Sample for drinking purpose.

Dear Sir,

Please find herewith the test report of the sealed water sample sent by you vide above mentioned reference & subject.

TESTING REPORT

S.No.	Parameters/Tests	Laboratory Results
1	Temperature	22.4°C
2	Turbidity	0.5N.T.U.
3	Colour	Absent
4	Odour	Un-objectionable
5	Taste	Un-objectionable
6.	pH Value	6.58
7	Acidity	04 mg/l as CaCO ₃
8	Alkalinity	36 mg/l asCaCO ₃
9	Total Solids	298 mg/l
10	Dissolved Solids	294 mg/l
11	Suspended Solids	04mg/l
12	Chlorides(Cl ⁻)	90 mg/l
13	Hardness	120 mg/l asCaCO ₃
14	D.O.	4.2 mg/l

Remarks:

- The above tested Parameters of water sample complies with the drinking water standard as laid down in IS:10500-2012. Hence it can be comnated that Water Sample is found fit for drinking purpose only on the above tested parameters.
- Testing charges of Rs. 4910/- deposited vide UTR No. 224918161926 dated 06-08-2022.
- Sample received on 30-08-2022.
- Testing date/Report generated on: 08-09-2022/15-09-2022.

Prof. A.K. Agarwal
(Prof. I/c PHE Lab)

Dr. M.K. Trivedi
(H.C.E.D.)

Forwarded:

This Testing / Consultancy report is forwarded on the recommendations of the Department
Responsibility of Test / Consultancy Report lies with the concerning department.

Chitran No. 224918161926

Date: 8.8.22

DIRECTOR

Sr. No.: 2022 **025**

Book No.: MITS TCR/XXXII

Accounts Officer

19/9/22

